

TYPICAL CEMENT CERTIFICATE

Masonry Cement type

N

Physical tests

Time of set (minutes)

Gillmore

Initial..... 185

Final..... 350

Vicat

Initial..... 115

Final..... 325

Compressive strength (MPa)

7 days..... 10.4

28 days..... 12.3

Autoclave expansion (%)..... 0.04

Water retention (%) 79

Air content (%)..... 18

**We hereby certify that the cement delivered complies with the
CSA Standard A3000-13 requirements section A3002-13, Type N.**

For any information regarding this certificate, please contact our technical service at (418) 329-2100, ext. 3276.

**Michel Chabot, Eng.
Chemist Engineer**